

**DEPARTMENT OF TRANSPORTATION**

DES-OE MS #43  
1727 30TH Street, 2ND Floor  
Sacramento, CA 95816



**\*\* WARNING \*\* WARNING \*\* WARNING \*\* WARNING \*\***  
**This document is intended for informational purposes only.**

Users are cautioned that California Department of Transportation (Department) does not assume any liability or responsibility based on these electronic files or for any defective or incomplete copying, excerpting, scanning, faxing or downloading of the contract documents. As always, for the official paper versions of the bidders packages and non-bidder packages, including addenda write to the California Department of Transportation, Plans and Bid Documents, Room 0200, P.O. Box 942874, Sacramento, CA 94272-0001, telephone (916) 654-4490 or fax (916) 654-7028. Office hours are 7:30 a.m. to 4:15 p.m. When ordering bidder or non-bidder packages it is important that you include a telephone number and fax number, P.O. Box and street address so that you can receive addenda.

May 6, 2003

07-LA-210-76.0/77.7  
07-4H5304  
ACIMG-210-1(772)E

Addendum No. 1

Dear Contractor:

This addendum is being issued to the contract for construction on State highway in LOS ANGELES COUNTY IN SAN DIMAS FROM 0.3KM NORTH OF VIA VERDE OVERCROSSING TO ROUTE 10/57/210 SEPARATION.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on May 15, 2003.

This addendum is being issued to revise the Notice to Contractors and Special Provisions.

In the Special Provisions, Section 10-1.19, "PILING," subsection "GENERAL" the following paragraph is added after the third paragraph:

"Difficult pile installation is anticipated due to the presence of high ground water and the requirement of pile embedment into rock. Moderate to minor caving is anticipated during pile construction."

In the Special Provisions, Section 10-1.19, "PILING," subsection "CAST-IN-DRILLED-HOLE CONCRETE PILES" the following paragraph is added after the second paragraph:

"Concrete placement for construction of cast-in-drilled-hole concrete piling shall be completed within the same day that excavation of the drilled hole has been completed."

To Proposal and Contract book holders:

Attached is a copy of the Materials Information (Geotechnical Design Report).

Indicate receipt of this addendum by filling in the number of this addendum in the space provided on the signature page of the proposal.

Submit bids in the Proposal and Contract book you now possess. Holders who have already mailed their book will be contacted to arrange for the return of their book.

Inform subcontractors and suppliers as necessary.

Addendum No. 1  
Page 2  
May 6, 2003

07-LA-210-76.0/77.7  
07-4H5304  
ACIMG-210-1(772)E

This office is sending this addendum by UPS overnight mail to Proposal and Contract book holders to ensure that each receives it. A copy of this addendum and the modified wage rates are available for the contractor's use on the Internet Site:

**[http://www.dot.ca.gov/hq/esc/oe/weekly\\_ads/addendum\\_page.html](http://www.dot.ca.gov/hq/esc/oe/weekly_ads/addendum_page.html)**

If you are not a Proposal and Contract book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,

ORIGINAL SIGNED BY

REBECCA D. HARNAGEL, Chief  
Office of Plans, Specifications & Estimates  
Office Engineer

Attachments